



ENERGY
INSTITUTE
Colorado State University

- **Analysis & Recommendations for Entusi
Retreat Center Electrical System**

Daniel Zimmerle, David Trinko
Colorado State University
February 24, 2017



Electrical System Agenda

- Hybridizing the Entusi Electrical System
- Expanding electrification to nearby villages

Time permitting:

- Simulation overview.
- Failure analysis

Introduction


- “Hybridize” Entusi electrical system:
 - Solar photovoltaic (PV) array
 - Engine-generator set (genset)
 - Battery storage

Current system

- Run hours kept at a minimum
- Retreat center without power much of the day
- Noise whenever electricity required

After hybridization:

- Generator started as needed (control to be developed)
- Electricity available all day
- Noise only when generator required





Introduction

- Goals of hybridization:
 - Reduce generation noise
 - Reduce fossil fuel dependence
 - Improve site sustainability
- Establish Entusi as a model microgrid facility & training location



Current Entusi Power System


- Two major types of loads:
 - Small, frequently switched
 - Phone and laptop charging
 - Some lights
 - Small appliances
 - Large, on for extended periods
 - Thermal loads:
 - Oven (5.5 kW),
 - Water heaters (7.5 kW total)
 - Some lights

Current Entusi Power System

Load Type	Peak Power Draw (kW)
Lighting	1.5
Water Heaters	7.5
Oven	5.5
Water Pump	0.5
Power Sockets	3.0
Refrigeration	0.5
Total	18.5

- Conclusion: Generator is properly sized if all loads are on concurrently (not a likely occurrence)

Measured Data for Dec. 30, 2016



Circuit 1: Dining building; Circuit 2: tent and bathroom on one side




Approaches for Hybrid System

- 1) Do nothing
- 2) Add PV & battery
 - All current loads stay the electric
 - Generator kicks in for larger loads
- 3) Add PV & battery + *Convert oven and/or water heaters to LPG (propane) units*
 - Engine runs less frequently
 - Reduce size/cost of PV/battery components

Hybridizing Current System (Case 1)

- Install PV array and battery system (keep existing generator)
 - 18.5 kW PV (~100 square meters)
 - 78 kWh battery



Hybrid System with Thermal Load Conversion (Cases 2-4)

- Replace oven and/or water heaters with LPG-powered units to reduce electric load
- Install PV array and battery system (keep existing generator)

	PV Size (kW)	Battery Size (kWh)	PV Array Size (ft ²)
Case 2: Replace Oven	15.0	64.5	90
Case 3: Replace Water Heaters	9.5	40	60
Case 4: Replace All Heating Loads	5.5	25	30

Current and Predicted Fuel Costs

		Diesel	LPG
Weekly Cost	Peak (5 mo/yr)	\$160	\$43
	Off Peak (7 mo/yr)	\$43	\$22
Unit Cost		\$0.90/liter	\$3.00/kg

Reported current weekly fuel costs

	Generator Weekly Fuel Cost	Appliance Weekly Fuel Cost
Case 1: No Replacements	\$43	\$0
Case 2: Replace Oven	\$42	\$62
Case 3: Replace Water Heaters	\$0	\$174
Case 4: Replace All Heating Loads	\$0	\$236

Predicted weekly fuel costs for optimized hybrid system (average)

Hybrid System Simulation

- Cost Measurements:

- Levelized cost of electricity ($LCOE_l$, \$/kWh)

- $LCOE_l = \frac{\text{Implementation Cost} + \text{Total Generator Fuel Cost}}{\text{Total Electricity Consumed}}$

- Levelized cost of energy ($LCOE_n$, \$/kWh)

- $LCOE_n = \frac{\text{Implementation Cost} + \text{Total Fuel Costs}}{\text{Total Electricity Consumed} + \text{Total Heat Consumed}}$

- Applicable when thermal loads served by LPG units

10% discount rate, 3% diesel fuel inflation

Hybrid System Lowest Cost Configurations

	PV Size (kW)	Battery Size (kWh)	Generator Hours (avg/day)	Install Cost	LCOEI (\$/kWh)	Implementation + Generator Run Cost	LCOEn (\$/kWh)	Implementation + Total Fuel Cost
Case 0: No Hybrid System	0.0	0	10.0	\$0	\$0.758	\$123,000	\$0.758	\$123,000
Case 1: No Replacements	18.5	78.0	0.2	\$86,000	\$0.556	\$91,000	\$0.556	\$91,000
Case 2: Replace Oven	15.0	64.5	0.0	\$81,000	\$0.605	\$85,000	\$0.570	\$121,000
Case 3: Replace Water Heaters	9.5	40	0.0	\$54,000	\$0.821	\$57,000	\$0.363	\$119,000
Case 4: Replace All Heating Loads	5.5	25	0.0	\$42,000	\$0.990	\$45,000	\$0.380	\$142,000





ELECTRIFICATION OF SURROUNDING AREAS





Electrification of Surrounding Areas

- During CSU's visit, performed survey of nearby residential areas
- Main observations:
 - 1) Housing density close to Entusi is too low to merit connecting to Entusi's system
 - 2) Highest housing density areas also show greatest capability/desire to purchase electricity (some already have solar panels)
 - 3) Utility line ends just 0.5 km from high density housing area (major risk factor)








End of Line

500 m






How we got the answers

SIMULATION OVERVIEW

Measured Data for Dec. 30, 2016



Circuit 1: Dining building; Circuit 2: tent and bathroom on one side




Data Description: Load Measurements

- Power draws measured during CSU's visit: Dec. 30 and 31, 2016
- Useful for validating on/off times for different loads
- Limits to applicability of data
 - Not typical loading during visit
 - Small sample (only 2 full days)
 - Uncertainty in sensor measurement

Load Simulation

- Peak season profile for current load configuration:





Simulation and Analysis

- 2 components to simulation:
 - 1) Load simulation
 - 2) Hybrid system generation simulation
- Both components: hourly simulation for a span of 20 years



Load Simulation

- Probability that each load is on during each hour of the day
- Peak and off-peak seasons
 - Staff testimony, observations from visit, measured data
- Create hourly load profile for 20 years



Hybrid System Simulation

- Use solar irradiation data from Kigali, RW
- Each hour:
 - 1) Power from PV serves load
 - 2) Extra PV power charges battery *or* extra load served by discharging battery
 - 3) Generator serves remaining load

Hybrid System Simulation

- Salient outputs:

- Levelized cost of electricity ($LCOE_l$, \$/kWh)

- $$LCOE_l = \frac{\text{Implementation Cost} + \text{Total Generator Fuel Cost}}{\text{Total Electricity Consumed}}$$

- 10% discount rate, 3% diesel fuel inflation

- Total installation and running costs

- Average daily generator runtime (hours)

- Levelized cost of energy ($LCOE_n$, \$/kWh)

- $$LCOE_n = \frac{\text{Implementation Cost} + \text{Total Fuel Costs}}{\text{Total Electricity Consumed} + \text{Total Heat Consumed}}$$

- Applicable when thermal loads served by LPG units



Hybrid System Simulation

- Costs estimated using unit prices:
 - PV array: \$2/watt (\$2,000/kW)
 - Battery: \$350/kWh
 - Generator fuel: \$2/hour generator runs
 - Assuming constant rate of fuel consumption, as reported by staff
- Current system estimated cost of electricity: ~\$0.35/kWh



Hybrid System Simulation

- Simulation run for many combinations of PV array and battery sizing
- Optimal configuration for each case: lowest $LCOE_l$

Hybrid System Lowest Cost Configurations

	PV Size (kW)	Battery Size (kWh)	Generator Hours (avg/day)	Install Cost	$LCOE_i$ (\$/kWh)	Implementation + Generator Run Cost	$LCOE_n$ (\$/kWh)	Implementation + Total Fuel Cost
Case 1: No Replacements	18.5	78.0	0.2	\$86,000	\$0.556	\$91,000	\$0.556	\$91,000
Case 2: Replace Oven	15.0	64.5	0.0	\$81,000	\$0.605	\$85,000	\$0.570	\$121,000
Case 3: Replace Water Heaters	9.5	40	0.0	\$54,000	\$0.821	\$57,000	\$0.363	\$119,000
Case 4: Replace All Heating Loads	5.5	25	0.0	\$42,000	\$0.990	\$45,000	\$0.380	\$142,000



Hybrid System Optimal Configurations

- Overall optimum configuration (minimum $LCOE_{||}$):
 - Case 1, retain electric oven and water heaters
 - \$0.556/kWh
 - PV array: 18.5 kW (\$37,000)
 - Battery: 78 kWh (\$27,300)
 - Generator: runs average of 0.2 hours/day (i.e. runs rarely to serve peak loads)

Other Considerations

- $LCOE_t$ may not be most important metric
- E.g.: minimize up-front cost, minimize $LCOE_n$

	Initial Implementation Cost	$LCOE_n$ (\$/kWh)
Case 1: No Replacements	\$86,000	\$0.556
Case 2: Replace Oven	\$81,000	\$0.570
Case 3: Replace Water Heaters	\$54,000	\$0.363
Case 4: Replace All Heating Loads	\$42,000	\$0.380



ADDITIONAL ANALYSIS




Failure Analysis

- Selection of potential failure modes for hybrid system:
 - 1) Inverter failure
 - 2) Battery failure
 - 3) Generator failure


Inverter Failure

- No power from PV/battery system
- Generator serves load independently
 - Not a problem if keep current generator




Battery Failure

- No electricity storage
- PV and generator must serve load
 - Generator must run more




Generator Failure

- PV/battery system must attempt to serve load
 - Current system has no safeguard against this: hybrid system more robust



Thank You!



Contact

Dan Zimmerle

dan.zimmerle@colostate.edu

970-581-9945



ENERGY
INSTITUTE

Colorado State University



energy.colostate.edu/p/svm